

Ohio Department of Transportation

Prebid Questions

Project No. 070016

Sale Date - 1/10/2007

Question Submitted: 1/2/2007

Question Number: 1

Ref. Nos 37 and 48, Removal of debonded existing variable thickness conc. o/l, provides for a total of 756 sy for Struct Nos. VIN-32-748 L&R. This area of debonded exist variable is 50% of the deck areas of the existing structures. Usually, debonded exist. variable area is about 5% of the actual deck area. Please review.

Question Submitted: 1/3/2007

Question Number: 2

There is no 614 WZ Edgeline as a bid item. It seems that there should be since the traffic is being shifted 4 feet in all of the phases. If WZ Edgeline is required, should it be paint or tape? The only WZ pavement markings set up in the plans is stop bars. Please clarify what ODOT desires and under what bid item it should be included.

This item is to be included in the lump sum bid price for item 614 - maintaining traffic. The note on sheet 2 as well as the spec. book states unless seperately itemized all items are included with item 614 for payment.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.