

Ohio Department of Transportation

Prebid Questions

Project No. 090471

Sale Date - 10/21/2009

Question Submitted: 10/12/2009

Question Number: 1

On page 21-General Summary, item-Aggregate base there are 16 cy carried from sheet 2. On sheet 2 the only item equaling 16 cy is 301 asphalt base. Is this a plan error and should the correct qty's be 77 cy of item 301 and 109 cy of 304?

Question Submitted: 10/15/2009

Question Number: 2

Please review the reinforcing steel list for VIN-327-1249 bar marks S805 to S807 which are supposed to be mechanically spliced. I can not match the quantities on detail drawing 54/59. Also, there is no S808 in the list as shown in the detail.

Question Submitted: 10/16/2009

Question Number: 3

In reference to pay item #95 SLG OF CONC SURF (EPOXY-URETHANE) Inspection of the existing structure to be sealed reveals that it is badly deteriorated with extensive surface spalling. Are the required partial depth repairs to be incidental to this item? It would seem that this work goes beyond surface prep.

The only exposed concrete on this section of the project is the existing wingwalls, as shown in the plans, which are in very good condition. Please bid the sealing as shown in the plans

Question Submitted: 10/8/2009

Question Number: 4

Are we allowed to use Galvization as a pile encasement option? If so, would it be paid under the encasement item or the piling (i.e. non-performing the encasement item)

Piles shall be encased as shown in the plans.

Question Submitted: 10/8/2009

Question Number: 5

All 3 structure require twmp pavements for maintaining traffic. The 0682 MOT drawings show the temp pavement to remain. The MOT drawings for the other 2 structures do not address this. Are we allowed to leave the temp pavement in place for the 0859 & 1249 structures?

All Item 615 - Pavement for Maintaining Traffic shall be removed as per Construction & Materials Specifications unless noted in the plans to remain.

Question Submitted: 9/30/2009

Question Number: 6

Can the existing bridge drawings be posted online?

ftp://ftp.dot.state.oh.us/pub/Districts/D10/Vinton_278/

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.