

Ohio Department of Transportation Prebid Questions

Project No. 070376

Sale Date - 8/1/2007

Question Submitted: 7/24/2007

Question Number: 1

On page 7 of the plans there is a detail for Ref. No. 1 Pavement Repair. The detail shows 14" to 17" existing asphalt, and replacing that with 12" of asphalt. Is the intent to be a full depth repair at 14" to 17" or partial depth as shown (12" depth)?

The total full depth repair will be the 14" to 17" of existing asphalt as stated in the plans.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.