

Ohio Department of Transportation

Prebid Questions

Project No. 060241

Sale Date - 5/17/2006

Question Submitted:

Question Number: 1

1. ROW plans show ROW and centerline Monuments (8 total) but no pay item. Will ODOT install these? 2. Qty for Commercial Fertilizer in addendum #1 is wrong should be 1.4 tons.

A1) ODOT will set these monuments after construction. A2) Thank you for pointing out this error in quantity. Because the dollar value of the error is small relative to the value of the entire project, the Department will not delay the sale to issue an addendum. Please prepare your bid based upon the quantity in the bidding documents.

Question Submitted:

Question Number: 2

1. Sheet 9 Traffic Notes- notes contain blank spaces where information should have been filled in. 2. various x-sections - lack dimensions, ex. sheet 29 no slope drain dimensions

1) Quantities have been provided in the general summary but not detailed on this sheet. If no quantity shows on the general summary, assume no quantity. 2) Slope drains in this situation have to be installed where they fit and length varies. Aside from having the outlet at the lowest point they are fluid and dimensions are near meaningless. Quantities provided on the General Summary

Question Submitted: 5/15/2006

Question Number: 3

Is PG 64-28 the correct binder for items 301,448-2 and 448-1.

Please bid using the 64-28 binder.

Question Submitted: 5/3/2006

Question Number: 4

The notes on sheet 9/60 do not give a contact for law enforcement officers. Who are we to use for LEOs? and, could a bid item be added for these hours?

Question Submitted: 5/3/2006

Question Number: 5

The notes on sheet 9/60 do not give a contact for law enforcement officers. Who are we to use for LEOs? and, could a bid item be added for these hours?

Question Submitted: 5/3/2006

Question Number: 6

There is a very complex temporary signal system on this job in order to maintain traffic. Could ODOT please add a bid item for work zone traffic signals?

Question Submitted: 5/8/2006

Question Number: 7

Re: Item 7 - Granular Embankment, As Per Plan.

Because this material will be placed along a 1:1 slope it will not be possible to place the aggregate exactly 2 feet wide as depicted on the cross sections.

Will ODOT pay ticket quantity based on a conversion factor, or is it your intent to field measure this quantity for payment?

We will pay ticket amount for this item.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.