

Ohio Department of Transportation

Prebid Questions

Project No. 100310

Sale Date - 5/27/2010

Question Submitted: 5/14/2010

Question Number: 1

Section details shown on page 11 of 13 indicates a saw-cut and removal of one foot of the existing paved shoulder, this design is consistent with a number of other recent projects which the proposed concrete pavement was abutting existing asphalt pavement. On this project the proposed concrete pavement is abutting existing concrete pavement. Is it the department intention to remove the one foot of existing concrete shoulder (this will require a removal of 15' to 20" of existing pavement) and replace it with the proposed concrete pavement.

See Forthcoming addendum.

Question Submitted: 5/17/2010

Question Number: 2

Once the existing pavement is sawed and removed, is the new pavement to be doweled to the existing?

Please refer to Addendum 1. The existing pavement is no longer being sawed. The proposed pavement will be butted up to existing with NO dowels.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.